

PURAFIL ENVIRONMENTAL CORROSION REPORT

02-Jun-2010

Company: 110387

Sales Order #: C002682
 CCC Panel #: P67446
 Date In: 08-May-2010
 Date Out: 21-May-2010
 Days In Service: 13

Room Area ID:
 Reference #:



CCC Panel # P67446
ISA Class G2 Moderate
Copper Corrosion 478 Å/30 Days
Silver Corrosion 1638 Å/30 Days

(see next page for complete analysis)

Summary for PURAFIL CCC # P67446

The electrolytic reduction analysis on Corrosion Classification Coupon #P67446 shows the presence of moderate concentrations of contaminants in the environment tested. The hydrogen sulfide level is expected to range between 3 and 10 ppb and the sulfur dioxide level between 10 and 100 ppb. The effects of corrosion are measurable and may be a factor in determining equipment reliability.

Your local representative for additional information and assistance is:
 Environmental Health and Eng
 117 Fourth Avenue, Needham MA 02494, USA
 tminegishi@eheinc.com

Purafil, Inc. / 2654 Weaver Way, Doraville GA 30340 USA / (770) 662-8545 / (770) 263-6922
 Email: purafil@purafil.com / Internet: http://www.purafil.com

Displaying Page 1 [Display Page 2](#)

PURAFIL CCC # P67446 Analysis Results

Corrosion Film Composition				Gold Coupon - Magnified 20x
	Projections			
	30 Days	1 Year	5 Year	
Copper Films				
Cu ₂ S	0 Å	0 Å	0 Å	
Cu ₂ O	313 Å	626 Å	1070 Å	
Unknowns	165 Å	330 Å	564 Å	
Totals	478 Å	956 Å	1634 Å	
Silver Films				
AgCl	0 Å	0 Å	0 Å	
Ag ₂ S	1554 Å	18921 Å	94606 Å	
Unknowns	84 Å	1025 Å	5127 Å	
Totals	1638 Å	19946 Å	99733 Å	

Gold Pore Corrosion:
Note: 1000 Å = 0.1 micron

Equipment Reliability Correlation
(ISA Standard S71.04-1985 for Copper)

